Effect of Coagulants on Electrochemical Process for Phosphorus Removal from Activated Sludge Effluent

AR Mesdaghinia¹, *D Rabbani², S Nasseri³, F Vaezi³

¹Center for Environmental Research, Tehran University of Medical Sciences, Iran ²Dept. of Environmental Health, School of Medical Sciences, Tarbiat Modarres University, Tehran, Iran ³Dept. of Environmental Health, School of Public Health, Tehran University of Medical Sciences, Iran

Abstract

According to Environmental Protection Organization of Iran, maximum permissible concentration of residual phosphorus in treated municipal wastewater is 1 mg/l-P. The total average phosphorus concentration in raw municipal wastewater is about 8 mg / l; about 70 percent of the incoming phosphorus normally is discharged with secondary treatment plant effluents. In this research, the role of adding different kinds of coagulants on phosphorus removal efficiency of an electrochemical process was investigated. The research is a bench scale experimental type using batch system for elec. process with direct current. Samples were collected from an extended aeration effluent. The used electrode was steel type and its total effective area was 336 cm². In each run 1500 ml of sample was placed in an electrolytic cell equipped with magnetic stirrer. The results show that phosphorus removal efficiency increases by increasing of DC and reaction time. Minimum rate of current/percentage of removal was obtained for 0.6amp current and under the same conditions minimum rate of reaction time/percentage of removal was provided in 15 min. In 6min reaction time and 0.6amp current, adding poly aluminum chloride (PAC) up to about 27 mg/l could improve the efficiency up to about 50%. But under the same condition, similar results were not observed in 12min reaction time. Besides, adding alum or ferrous sulfate showed similar behavior to PAC. Electrochemical treatment without addition of coagulants and thereby without any changes on the primary characteristics of the sample can remove the phosphorus up to about 93%. But in the case of sufficient reaction time for electrochemical process, adding coagulants can not improve the efficiency and in comparison to a chemical precipitation alone, the use of electrochemical treatment can not reduce the required doses of coagulants in short reaction time.

Keywords: Phosphorus, Electrochemical process, Wastewater, Coagulants, PAC

Introduction

to Environmental According Protection Organization of Iran, maximum permissible concentration of phosphorus in treated municipal wastewater for discharge is announced to be 1 mg/l(1). Like nitrogen, P is a nutrient for micro and macroscopic plants thus it has important role in creating eutrophication of surface waters (2). The average concentration of total P in raw municipal wastewater is 8mg/l, about10% of it, is removed in primary sedimentation and the other 10-20% in biological treatment, SO the remainder 70% is often discharged bv secondary effluent (3). Common forms of P in

 $(PO_4^{+3}).$ orthophosphate are wastewater polyphosphates and phosphates bonded to organic compounds. The last compounds release orthophosphate in aqueous solution too (4). Nearly all the P-content of wastewater and natural waters may appear as phosphate (5). It is obvious that advanced wastewater treatment facilities have to be employed to meet the discharge standard of P. The number of these facilities has increased considerably from the beginning of 1970s (6). There are various methods for P-removal but electrochemical method that is a valuable alternative has been used less. Indeed, this method has been used successfully in the treatment of phenol containing wastewaters, rinse water of electroplating, Cr & Zn removal from water destined for cooling towers and destabilization of colloidal suspensions (7-10). Also, this method has proved to have good efficiency in electrochemical reduction of halogenated compounds by using graphic electrode (11). In the treatment of wastewater from olive oil factories, E oxidation can reduce both the COD and sodium chloride to 500mgl⁻¹ from the initial concentrations of 20000 and 7000 mgl⁻¹ and thereby decrease the dilution ratio about 40 times (12). This method is also very effective in color and CODs removal from textile wastewater in 8-10 min reaction times and with less pH dependency (13). Another study indicates that the efficiency of this system is about 85-92% for COD and 85% for DOC removal from textile wastewater (14). Besides, it has reported for a novel electrolytic process using ionic electrode to be effective for phosphate recovery on anode surface (15). In this study, the role of coagulant addition on electrochemical p – removal from effluent of an activated sludge system has been investigated.

Materials and Methods

This research is a bench scale experimental type study, using a batch system of electrochemical process with direct current electricity. Cathode and anode were each made of 4 steel pieces, 1.5 cm apart and submerged in wastewater sample.

An ammeter and a voltmeter controlled the power input for this system. In each run, 1500 ml sample was poured in the electrolytic cell equipped with magnetic stirrer. The total effective area of used electrodes was 336 cm². (Figure 1) shows the sectional view of the electrolytic cell and other equipment used in this study as follows:

1. Adjustable D.C. power supply in the range of 0-40 ampere coupled with an A.C. /D.C adaptor

2. Industrial type digital ammeter/voltmeter

3. Paraleled anodes (steel pieces)

4. Paraleled cathodes (steel pieces)

5. Magnetic bar stirrer

6. Mechanical sampling valve

7. P.G. vessel (3 litter max)

8. Digital magnetic stirring controller 0-300 rpm

Fig. 1: Sectional view of the employed electrolytic cell

For avoid adjust, pH, temperature and electrical conductivity of effluent, the initial values of these parameters were not changed. The total phosphorous of all samples has been determined according to the ascorbic acid method as outlined in Standard Methods (5). The reaction time was at first 10 min and steel electrode had been employed for optimum electrical current determination. For the second stage, the effect of reaction time on P- removal had been examined using the determined optimum current (0.6 amp). Besides, the effect of coagulant

addition $[Al_2 (SO_4)_3, 18H_2O-FeSO_4, 7H_2O]$ and PAC (poly aluminum chloride) had been investigated separately for reaction times of 6 and 12 minutes.

Results

Concentrations of total Phosphorus after electrochemical processes on different electrical currents presented in table 1. In this step the other conditions were same for all runs.

Table 1: concentrations of T.P after Electrochemical Process on different electrical current	ts
--	----

E	.C. Process	Reaction	Electrical	Residual	Phosphorous
С	haracteristics	time	current	Phosphorous	removal
sa	mple	(sec)	(mamp)	(mg /l)	%
A	.S. effluent	-		5.95	0.00
R	un 1	600	300	4.14	30.42
R	un 2	600	600	1.69	71.60
R	un 3	600	1200	0.88	85.21
R	un 4	600	3600	0.44	92.61
R	un 5	600	5100	0.42	92.94
R	un 6	600	12000	0.41	93.11

AR Mesdaghinia et al: Effect of...





Table 2: shows concentrations of T.P after electrochemical process on different reaction times.

 Table2-concentrations of T.P after Electrochemical Process on different reaction times

E.C. Process Characteristics sample	Reaction time (sec)	Electrical current (mamp)	Residual Phosphorous (mg /l)	Phosphorous removal %
A.S. effluent	-	-	5.37	-
Run 1	1800	600	0.65	87.90
Run 2	1500	600	1.60	70.20
Run 3	1200	600	1.90	64.62
Run 4	900	600	1.93	64.06
Run 5	600	600	3.43	36.13
Run 6	300	600	5.34	0.56



The changes in total P- removal efficiency versus reaction time can be seen in figure3.

According to this figure, the minimum ratio of reaction time to 1% P- removal is belonging to 15 min reaction time. Besides, P-removal efficiency is improved by increasing the time of reaction and about 88% removal could be achieved in 30 minutes. (Table3) represents

concentrations of T.P after electrochemical process on different PAC doses for two reaction times of 6 and 12 minutes. The effect of increasing PAC dose on P- removal efficiency can be seen in figure 4 for above reaction times.

Table 3: concentrations of T.P after Electrochemical Process on different PAC doses

Phosphorus Concentration	Total Phosphorus remained (mg/l-P)		
PAC doses (mg/l)	6min.reaction time*	12min.reaction time**	
0.00	1.49	0.56	
3.33	0.88	0.53	
6.67	0.75	0.53	
13.33	0.64	0.56	
26.67	0.57	0.49	

**Initial T. P con. of effluent=2.30mg/l-P.



In reaction time of 6 min, 27 mgL⁻¹ PAC additions, can improve the efficiency of P-removal up to 50%, but similar improvement cannot be gained in12min. Tables 4 - 5 show the concentrations of T.P after electrochemical process on different alum and ferrous sulfate

doses respectively. Finally, figures 5 and 6 shows the effects of alum and ferrous sulfate feeding on P- removal efficiency. Again, both of these coagulants have a relatively similar behavior to PAC electrochemical process.

Table 4: concentrations of T.P after Electrochemical Process on different Alum doses

Phosphorus Concentration	Total Phosphorus (mg/l-P)	Total Phosphorus remained (mg/l-P)		
Alum doses (mg/l)	6min.reaction time *	12min.reaction time**		
0.00	1.49	0.5		
21.78	0.98	0.53		
43.56	0.67	0.54		
87.11	0.65	0.48		
174.22	0.64	0.49		

**Initial T.P con. of effluent=1.93mg/l-P

Table 5: concentrations of T.P. after Electrochemical Process on different Ferrous Sulfate doses

Phosphorus Concentration	Total Phosphorus remained (mg /l-P) *			
Ferrous sulfate	6min.reaction time	12min.reaction time		
doses (mg/l)	1.40	0.61		
0.00	1.49	0.61		
9.2	1.37	0.63		
18.4	1.04	0.52		
36.8	0.88	0.41		
73.8	0.72	0.39		

*Initial T. P con. of effluent=1.89mg/l-P



Discussion

Results of this study have indicated that the use of coagulant has no special advantage for electrochemical process of P- removal. Equal amounts of coagulants cannot improve Premoval efficiency in a same rate. Besides, and as it is seen in figure2, electrochemical treatment by itself can remove about 93% of P-content of effluent without need to change the initial characteristics of effluent samples. This consequence is similar to the result of the study conducted by J Naumczyk (14). The minimum ratio of electrical current to1% P-removal could be achieved at 0.6amp and the corresponding current density in this case is 1.78 m amp/ cm². According to figure 3 for this current density, the minimum reaction time for 1% P-removal is achieved when the reaction time is about 15minutes. The P-removal efficiency in this case is about 65%. So these conditions are not favorable to reduce P in excess of 5.6 mgL⁻¹ (3) in the effluent to the discharge standard. According to Peng and SH Lin (13), the efficiency of electrochemical process in COD removal can be increased from 21% to 56% by 40 mgL⁻¹ PAC addition. Figure 4 shows that by addition of 27 mgL⁻¹ PAC. P-removal efficiency has improved about 50% at the current density of 1.78 m amp/cm² (corresponding to 0.6 amp) and

in 6 minute reaction time, but this dose not suffice to meet the discharge standard, and has not a considerable effect on P-removal at 12 min reaction time (The increase in efficiency is only about 3%). In addition, results of treatment by the 2 other coagulants were relatively similar to PAC. As the gradient of P- removal is not constant versus coagulant concentration, the mentioned difference is not unsound. With the regard to the mentioned benefits for PAC (16) comparing results of PAC treatment with other coagulants indicates that PAC as it is expected is superior.

References

- 1. Environmental Protection Organization of Iran (2001). Executive Bylaws for Paragraph(C) of Article 104 and Article 134 of the Third -5 year plan of the Islamic Republic of Iran.
- McGhee T J (1991). Water supply and sewerage. 6nd Ed. McGraw-Hill. Singapore.
- Linsley R K, Franzini J B, Freyberg D L, Tchobanoglous G(1992).*Water resources engineering*. 4nd Ed. McGraw-Hill. Singapore.
- Hammer M J (1996). Water and Wastewater Technology 3nd Ed. Prentice -Hall. New Jersey.
- American Public Health Association, AWWA, WEF (1992). Standard methods for the examination of water & wastewater. 18nd Ed. Washington.
- Metcalf & Eddy (2003). Wastewater Engineering, Treatment, Reuse. 4nd Ed. McGraw-Hill. New York.
- Comninellis C (1992). Electrochemical treatment of wastewater containing phenol. Process Safe Environmental Protection, 70 (B4): 219-224.

- 8. Poon CPC (1979). *Electrochemical treatment of planting rinses water*. Effluent Water Treatment Journal, 19(7): 351-355.
- Schmitt C R, DeMonbrun J R (1975). Electrochemical Destruction of Chro- mate and Zinc from Cooling-Tower Water. Oake Ridge Y-12Plant, Y-DA--6514: 15PP.
- 10. Tunturi PJ (1976). Electrochemical treatment of process Wastewater containing colloidal particles. International Chemical Engineering. 16(2): 222-228.
- 11. Schmal D, Van Erkel J, Van-Duin P J (1986). *Electrochemical reduction of halogenated compounds in process wastewater*. Electrochemical Engineering, Institution of Chemical Engineers Symposium, Series No 98 EFCE Event No 332 paper from 3-day Symposium: 281-291.
- 12. Vigo F, Avalle L, Paz M (1983). Disposal of vegetation water from Olive Oil Mills, Study of Electrochemical Oxidation (in Italian) .Riv Ital Sostanze Grasse, 60(3):125-131.
- 13. Sheng HL, Peng CF (1994). Treatment of textile wastewater by electrochemical method. Water Research, 28(2):277-282.
- 14. Naumczyk J (1996). *Electrochemical treatment of textile wastewater*. Water Science and Technology, 34(11): 17-24.
- 15. Sakakibara y, Nakajima H (2002). *Phosphorus removal and recovery by a novel electrolytic process* Water Science and Technology, 46 (11-12): 147-152
- 16. Sedigh EP (1998). Comparison of coagulant performance in the treatment of water and effluent of power plants. Industry Publication, 21:10-14



` م • م

www.SID.ir