

Application of an environmentally optimum cooling water system design in water and energy conservation

M. H. Panjeshahi; *A. Ataei

Department of Energy Engineering, Graduate School of the Environment and Energy, Science and Research Campus, Islamic Azad University, Tehran, Iran

Received 23 September 2007; revised 18 October 2007; accepted 29 February 2008; available online 10 March 2008

ABSTRACT: Recirculating cooling water systems consist of a cooling tower and heat-exchanger network which conventionally have a parallel configuration. However, reuse of water between different cooling duties enables cooling water networks to be designed with series arrangements. This will result in performance improvement and increased cooling tower capacity. Research on recirculating cooling water systems has mostly focused on the individual components. However, a particular design method represented by Kim and Smith accounts for the whole system interactions. In this study, the Kim and Smith design method is expanded and a comprehensive simulation model of recirculating cooling system was developed to account for the interaction between the cooling tower performance and the heat-exchanger network configuration. Regarding this model and considering cycle water quality through introducing ozone treatment technology, a modern methodology of recirculating cooling water system design was established and developed. This technique, called the integrated ozone treatment cooling system design, is a superior designed tool based on pinch analysis and mathematical programming. It also ensures maximum water and energy conservation, minimum cost and environmental impacts. Related coding in MATLAB version 7.3 was used for the illustrative example to get optimal values in cooling water design method computations. The result of the recently introduced design methodology was compared with the Kim and Smith design method.

Key words: *Environmental impacts, ozone treatment, pinch analysis, mathematical programming, heat-exchanger network*

INTRODUCTION

Recirculating cooling water systems (RCWS's) and once-through cooling water systems are used for the rejection of waste heat to the environment. Of these methods, recirculating cooling water systems are the most common ones because of their important role in conserving fresh water and reducing thermal pollution compared to once-through systems (Kim *et al.*, 2001). The process of cooling water system is that; cooling tower supplies the cooling water which goes through a network of coolers, usually of parallel configuration. However, reuse of cooling water between different cooling duties enables cooling water networks to be designed with series arrangements. This allows better cooling tower performance and increases cooling tower capacity in the context of new design. In RCWS design, any possible changes in each system component should be predicted properly. To achieve this, directly interacted cycle components should be accounted simultaneously (Smith, 2005). Pinch technology, as the

most common design tool, will be used. This technology is based on targeting prior to design and exploits conceptual understanding. Pinch technology in water system design has been developed through principle concepts to make opportunities for energy saving in process design, since it cannot be applied for energy conservational implications (Kim *et al.*, 2001). Previous researches on RCWS focused on the cooling system components individually, not the system as a whole. However, a simultaneous integration of RCWS components provides opportunity to achieve the optimum design. Kim and Smith (2001) developed a systematic design methodology of RCWS, KSD method, which accounts for the interactions between the cooling tower and heat-exchanger network. This research has expanded the original design methodology (KSD). The KSD methodology allowed the minimum cooling water flow rate to be participated in the performance parameters calculation and network configuration design, considering fix approach value as the cooling tower design variable. However, the

*Corresponding Author Email: abtinataei@gmail.com
Tel./Fax: +9821 4446 5383

minimum cooling water flow rate through the fix approach value does not necessarily ensure neither optimum value, nor the minimum cost of system. Furthermore, their proposed cooling tower model is presented to demonstrate the existing interactions within the cooling water systems, whereas the presented cooling tower model accounts for water temperature only and is not sensitive to flow rate changes. However, for the cooling system design, a comprehensive model is needed to determine an optimum water flow rate and temperature, which are the interacting performance parameters, as well as cooling tower behavior prediction under the various conditions. Moreover, for water and energy conservation, a technique such as increasing the cycle of concentration is not considered in the cooling water system design method (Kim and Smith, 2001). To increase the cycle of concentration, cooling water quality should be considered as an important parameter. The objective of this study was to introduce and develop a modern methodology to RCWS design, regarding the interaction between cooling tower performance and the heat-exchanger network configuration, not the cooling system components individually. It considers any probable changes in RCWS components and regards the effect on the whole cycle, providing predicted conditions of the exiting air and water (Kim and Smith, 2001). The model leads to a modern design methodology which is called "integrated ozone treatment cooling system (IOTCS)" design which accounts for optimal heat-exchanger network configuration, maximum water and energy conservation and minimum cost. Integrating ozone treatment to cooling water system leads to a cost-effective and environment-friendly RCWS design (Parker, 1998).

MATERIALS AND METHODS

Water quality and its significance

Water, as the main component of every cooling system, provides heat rejection opportunity for heat-exchanger network. Thus, the quality of the cooling and make-up water needs to be considered not only to achieve an optimum operational condition, but also for reducing the negative environmental impacts. In a cooling system, eventually, the minerals reach a cycle of concentration that will cause loss of efficiency due to scale formation or damage due to excessive corrosion. To conserve water and treatment chemicals, it is desirable to allow the dissolved minerals to reach

a maximum cycle of concentration. The cycle of concentration (π_C) is defined as the concentration ratio of a soluble component in the blow-down stream to that in the make-up stream (Heikkila and Milosavljevic, 2001).

$$\pi_C = \frac{X_B}{X_M} = \frac{M}{(B + D)} \quad (1)$$

The concentration of contaminants should be managed to control biological growth, corrosion and scale build-up. The maximum cycle of concentration will depend on the quality of make-up water (Parker, 1998). Chemical, physical and biological treatment processes are used to improve the make-up water quality to solve the problems relevant to cooling water treatment, such as scale formation, corrosion and bacterial growth. Of all the methods, non-chemical treatment methods could be considered as safe and environmentally responsible methods for the use of make-up water. Magnetic and electro-magnetic, electrostatic, electrolysis, ozonation and hydrodynamic cavitations are some of these non-chemical treatments.

Ozone water treatment

Ozone (O_3) has been recognized for nearly a century for its powerful ability to disinfect water. Cooling tower water must be treated to limit the growth of mineral and microbial deposits that can reduce the heat transfer efficiency of the cooling tower. The conditions in cooling towers can promote the growth of Legionella, which can exist in low concentrations in most water supply systems. Fig. 1 shows an integrated cooling tower with ozone water treatment unit (Parker, 1998). A cooling tower ozone treatment system compresses ambient air, then dries and ionizes it to produce ozone. The ozone is added to the circulating water in the tower to inactivate the infectious bacteria, algae and viruses in tower. Furthermore, microorganisms tend to accumulate in a bio-film on the sides and components of the cooling tower system, impeding heat transfer efficiency, increasing energy consumption (as the system has to work harder) and increasing maintenance costs. A frequent problem is the build-up of scale, mineral coatings that adhere especially well to the bio-film. Again the resulting build-up impedes system efficiency and could affect human health (Strittmatter, 2003). Conventional cooling tower water treatment




Fig. 1: Ozone treatment of cooling tower water

technologies include treatment with chemicals to remove microorganisms and scale and the blow-down of water to remove impurities. These operations both add to the cost of cooling tower operation and maintenance (Conner, 2005). Integration of ozone water treatment with the recirculating cooling water system gathering the cycle of concentration which decreases the concentration of insoluble components in circulating water (Viera *et al.*, 2000). It dramatically reduces the blow-down that, in turn, is environmentally constructive. Cooling water systems can be considered as energy conservation feeds opportunities (Alsheyab and Munoz, 2007). For maximizing water and energy conservation, ozone treatment should be integrated into the cooling tower. This also manages to drastic environment-friendly implications. The effect of ozone treatment integration on cooling system and IOTCS design is illustrated in the following example. During this research, an optimum cooling water system was designed to minimize the total cost while maximizing water and energy savings. To accomplish the objectives of this design, a cooling tower model was presented to predict the cooling tower performance parameters, water temperature and flow rate under various conditions provided by the heat-exchanger network. The model is then followed by the RCWS design, which is based on pinch analysis and

mathematical programming. This designed model, called the “integrated ozone treatment cooling system (IOTCS)”, considers the cycle water quality by involving ozone treatment to the cooling water system. By using this method, an optimum heat-exchanger configuration was obtained by introducing a feasible area concerning the constraints that were dictated through the whole cooling system and exploring the optimum water supply line regarding minimum total annual cost. The optimization model was based on a relaxed approach value which considered the defined feasible region to accomplish the optimum water supply line and cost-effective heat-exchanger configuration.

Mathematical modeling of cooling tower

To determine the interactions within the cooling system, RCWS modeling was introduced. The model includes RCWS components for an accurate prediction of the exiting air and water condition. In the presented mathematical modeling, a counter-current contact cooling tower with mechanical air draft was assumed. The presented new mathematical model accounts for a reliable representation of air water conditions. Fig. 2 shows the process input and output and the energy and mass balances for make-up and blow-down as follows (Castro *et al.*, 2000):




Fig. 2: Cooling system modeling




Fig. 3: Control volume

$$F_0 = F_1 - B + M \quad (2)$$

$$F_0 T_0 = (F_1 - B) T_1 + M T_M \quad (3)$$

The overall heat load of the cooling water network was also needed to determine the desired heat removal of the cooling tower (Fisenko *et al.*, 2004):

$$Q_{HEN} = F_2 C_P (T_2 - T_0) \quad (4)$$

Considering an elementary control volume in the fill or packing of a counter-flow, i.e. wet cooling tower (Fig. 3), mass balance for the control volume yields (Kröger, 2002):

$$m_a (1 + w) + (m_w + \frac{dm_w}{dz} dz) = m_a (1 + w + \frac{dw}{dz} dz) + m_w \quad (5)$$

Humidity ratio changes along the cooling tower height:

$$\frac{dw}{dz} = K_G (w_{out} - w_{air}) \quad (6)$$

where, K_G is the mass transfer coefficient of air (Kloppers and Kröger, 2005a). Several experimental measurements on heat and mass transfer coefficient in cooling towers have already been made. In air-water systems, the result is represented as a function of air and water flow rate (Smith, 2005):

$$K_G = a_1 m_a^b m_w^c \quad (7)$$

where, w_{air} is the humidity ratio of air and w_{out} refers to the humidity ratio of the interface (Hasan and Siren, 2002).

$$w_{out} = 0.622 \frac{P^s}{(P - P^s)} \quad (8)$$

$$w_{air} = \frac{E}{(w_{out} - w_{in})} \quad (9)$$

$$w_{in} = -\frac{C P a}{w_{ga}(WBT)} [T_{amb} - T_{WB}] + w_{sat}(WBT) \quad (10)$$

That $w_{ga(T)}$ is defined as below (Mann and Liu, 1999):

$$w_{ga(T)} = 2501.3 + 1.82T \quad (11)$$

It is assumed that the air leaves the tower at the saturation condition (Kloppers and Kröger, 2005b). The P^s is saturated pressure in Pascal (water vapor pressure at outlet air temperature given by the average of the inlet and outlet temperature of water) as per in Antoine equation (Heikkila and Milosavljevic, 2001):

$$\ln P^s = A_0 - \frac{B_0}{(T + C_0)} \quad (12)$$

The coefficients of the above equation are presented as follows (Kim and Smith, 2001):

$$\text{For } 0^\circ\text{C} < T < 57^\circ\text{C}, \\ A_0 = 23.7093, B_0 = 4111, C_0 = 237.7$$

The energy balance on control volume is:

$$m_a h_a + (m_w + \frac{dm_w}{dz} dz) C_P (T_w + \frac{dT_w}{dz} dz) = \quad (13)$$

$$m_a (h_a + \frac{dh_a}{dz} dz) + m_w C_P T_w$$

Neglecting the second order terms of equation (13) simplifies to:

$$m_w C_P \frac{dT_w}{dz} + C_P T_w \frac{dm_w}{dz} = m_a \frac{dh_a}{dz} \quad (14)$$

By substituting equation (5) with equation (6):

$$\frac{dT_w}{dz} = \frac{m_a}{m_w} \left(\frac{1}{C_p} \frac{dh_a}{dz} - T_w \frac{dw}{dz} \right) \quad (15)$$

The total enthalpy transfer at the air-water interface consists of an enthalpy transfer associated with the mass transfer due to the difference in vapor concentration and the heat transfer due to the difference in temperature (Kröger, 2002):

$$dQ = dQ_m + dQ_C \quad (16)$$

The enthalpy transfer is expressed by:

$$dQ_m = h_w \frac{dm_w}{dz} dz = h_w h_d (h_w - w) dA \quad (17)$$

The convective transfer of sensible heat at the interface is given by Kloppers and Kröger (2004):

$$dQ_C = h_d (T_w - T_a) dA \quad (18)$$

Water temperature drops along the cooling tower height which can be expressed as follows (Hollands, 2003):

$$\frac{dT_w}{dz} = \frac{m_a}{m_w} \frac{1}{C_p} \frac{dh_a}{dz} \quad (19)$$

The cooling tower effectiveness (e) is defined as the ratio of actual heat removal to the maximum achievable heat removal (Khan *et al.*, 2004).

The high effectiveness of cooling tower represents better cooling performance and high heat removal. Effectiveness is presented through the following expression (Khan *et al.*, 2003):

$$e = \frac{Q_{Act}}{Q_{Max}} \quad (20)$$

The outlet cooling water temperature, flow rate and evaporation ratio are all functions of tower air flow rate, wet bulb temperature, inlet water temperature and the flow rate (Khan and Zubair, 2004). The effect of each parameter, namely temperature difference along cooling tower (R) and flow rate (F_{in}), should be examined to achieve the optimum point. The result of the cooling tower modeling shows that decreasing the water flow rate of the cooling tower has a more significant effect on the effectiveness than decreasing the inlet temperature. To verify the results of the proposed model, the simulation results were compared with the experimental data (Table 1) (Bernier, 1994). The results shown in Table 1 demonstrates that when the cooling water inlet conditions are in high temperature and low flow rate, the cooling tower effectiveness increases, which indicates more heat removal from cooling tower will occur, that is, in such conditions, cooling tower obtains a lower cooling water outlet temperature. In the verification stage of the model, it was observed that the cooling tower model, used for

Table 1: Verification of cooling tower model

Experimental data	1	2	3	4
Air flow rate (t/h)	2.41	2.361	2.39	2.368
Water flow rate (t/h)	0.72	1.08	1.43	1.782
Water inlet temp. (°C)	36.70	32	29.30	27.90
Water outlet temp. (°C)	19.80	20.40	20.70	20.80
Make up flow rate (t/h)	0.042	0.050	0.040	0.047
Blow down flow rate (t/h)	0.0263	0.0207	0.0250	0.0197
Model output data	1	2	3	4
Dry air flow rate (t/h)	2.48	2.40	2.42	2.37
Blow down rate (t/h)	0.0224	0.0225	0.0222	0.0225
Make up rate (t/h)	0.045	0.045	0.045	0.045
Evaporation rate (t/h)	0.0224	0.0225	0.0222	0.2258
Pumping power (KW)	0.0284	0.0426	0.0565	0.0703
Heat rejection (mmW)	0.0143	0.0140	0.0125	0.0116
Exit air temp. (°C)	17.59	18.00	17.83	18.15
Water outlet temp. (°C)	19.81	20.44	20.66	20.82
Effectiveness (%)	63	52	30	26
Make up error (%)	0.06	-0.10	0.11	-0.04
Blow down error (%)	0.15	-0.08	0.11	-0.12
Temperature error (%)	0.05	0.19	-0.19	0.09

the design of cooling water system, is accurate enough to evaluate the tower performance and predict the effectiveness of the cooling tower system.

Objective function

In design targeting, the objective is to minimize the total annual cost (Kim *et al.*, 2001). Consequently, the defined objective function of the introduced design methodology was to determine total annual cost of the cooling tower including operational and capital cost (Kaiser *et al.*, 2005). The capital cost of cooling tower is as follows:

$$CC = 746.749(F_{in})^{0.79} (R)^{0.57} (A)^{-0.9924} (0.022T_{WB} + 0.39)^{2.447} \tag{21}$$

As shown in equation (21), the capital cost in \$/y, including chemical engineering index and annualisation factor, a function of water flow rate in t/h. The approach, range and wet bulb temperature are in °C. The operating cost of cooling tower:

pumping cost + fan cost + make-up cost + chemical treatment cost + blow-down treatment cost

$$OC = 2.4094 \times 10^{-3} (PP) + 44(F_{air}) + 110(F_{in}) + 2275.132(M) + 1138(B) \tag{22}$$

The operation cost includes the terms “cooling water pumping cost”, “air fan operation cost”, “make-up water cost”, “cycle cooling water chemical treatment” and “blow-down treatment cost”. For the water pumping cost, the terms “pumping power”, “electricity cost coefficient” and “conversion factor” are considered in the model. Air fan operation cost depends on air flow rate, electricity cost coefficient and related conversion factor. Make-up water cost is a function of water flow rate. Cooling water treatment cost also varies

according to flow rate. Operating cost consists of blow-down treatment cost as well. As a matter of fact, the cooling tower wastewater should be treated to meet the environmental standard specification. The cost of blow-down treatment depends on the amount of blow-down flow rate and the cost coefficient. Ultimately, the objective function is defined as the total annual cost. The optimization problem can be stated as follows:

$$Min TC = CC + OC \tag{23}$$

The operating cost and capital cost of the cooling tower differently affect the overall cost of cooling water systems, as shown in Fig. 4. The problem of targeting cooling water systems becomes an optimization problem to search for the optimal cooling line.

Model constraints

To establish the model constraints, first, the cooling water composite curve should be drawn. Cooling water streams depend on the heat load and the temperatures were graphed. All the cold streams are then summed up to figure out the composite curve (Smith, 2005). The cooling water supply line is shown for the maximum reuse of water, which means the possible series configuration of heat-exchangers. Fig. 5 shows the procedure for the composite curve graph and the targets for the maximum reuse of water flow rate. The point where the target supply line touches with the composite curve creates a pinch point. The interpretation of the pinch does not imply zero driving force for the heat transfer, but it is only a minimum driving force. Upon introducing constraints, the pinch point that will not cross the composite curve should be considered. The cooling tower cannot operate at temperatures above a specific water temperature due to operational problems related to cooling tower performance, such as packing decomposition. Therefore, temperature constraints should be imposed on the model. Fig. 6 shows the feasible region for cooling water systems, using the optimum cooling target line located between two limits. One limit is the minimum flow rate target and the other is the maximum flow rate target line, representing a parallel configuration. The slope and inlet/outlet temperature of the target cooling line are limited by the temperature conditions and the composite curve. It should be considered that for maximum water reuse cooling supply line construction, i.e. a minimum approach (TMA), is necessary.




Fig. 4: Cooling tower cost via water flow rate




Fig. 5: Cooling water composite curve and targeting for maximum reuse




Fig. 6: Temperature feasible region

The air flow rate is expressed in the following expression (Deng and Tan, 2003):

$$F_{air} = \frac{E}{w_{out} - w_{in}} \quad (24)$$

That inlet and outlet humidity ratios are both functions of temperature:

$$w_{in} = f(T_{WB}, T_{amb}) \quad (25)$$

$$w_{out} = f\left(\frac{T_{in} + T_{out}}{2}\right) \quad (26)$$

The evaporation rate is a function of water flow rate and temperature difference of cooling tower (Kim et al., 2001):

$$E = 0.00153(F_{in})(R) \quad (27)$$

The heat load of cooling system is:

$$Q_{HEN} = F_{in}C_p(T_{in} - T_{out}) \quad (28)$$

The design variables for the cooling tower construction are usually temperature range, approach temperature and water flow rate (Pascal and Marchio, 2003). The approach is more important than the flow rate and the range in achieving a high driving force for cooling. This is because the driving force becomes more limiting as the approach becomes narrow. Since cooling performance is influenced by the water flow rate as well as other factors, a cooling water system should be targeted by considering the effect of tower performance on cooling cost (Kloppers and Kröger, 2005c). Range definition:

$$R = T_{in} - T_{out} \quad (29)$$

Approach definition:

$$A = T_{out} - T_{WB} \quad (30)$$

Feasibility constraint on the inlet and outlet temperatures of cooling tower is:

$$T_{NR} \leq T_{in} \leq \text{Min} \{T_{MR}, T_{TL}\} \quad (31)$$

Cooling tower water outlet temperature varies between minimum approach value, considering wet bulb temperature and the minimum temperature of water stream at heat-exchanger network:

$$(T_{WB} + T_{MA}) \leq T_{out} \leq T_{MN} \quad (32)$$

Here, T_{MN} is the minimum temperature of heat-exchanger network with respect to ΔT_{min} of the network and T_{MA} is the minimum cooling tower approach.

$$T_{MN} = T_{HEN_{Min}} - \Delta T_{Min} \quad (33)$$

The feasible area for the inlet temperature of cooling tower is constructed as the region between non-reuse

of water at the heat-exchanger network, which is synonymous to a totally parallel configuration and maximum water reuse temperature considering cooling tower packing limitation (Qureishi and Zubair, 2006). In order to define the upper inlet temperature boundary, the minimum value between T_{MR} and T_{TL} (temperature limitation), that is determining by the tower packing type, should be selected. The analysis for optimization of the process ensures that the optimum water supply line temperature does not violate the temperature limitation. In order to reach a desired outlet temperature, a minimum approach for the wet bulb temperature of the ambient and the network minimum hot stream temperature should be taken into consideration, regarding the pinch point (Smith, 2005).

Feasibility constraints to avoid pinch crossing is:

$$T_{out} + R\left(\frac{Q_i^{Pinch}}{Q}\right) \leq T_i^{Pinch} \quad (34)$$

Feasibility constraints on the cooling water flow rate is:

$$F_{in}^l \leq F_{in} \leq F_{in}^u \quad (35)$$

F_{in}^l and F_{in}^u are the upper and lower limits of the water flow rate which are expressed at water temperature feasibility area of cooling tower. Pumping power is a function of water flow rate and can be calculated as the following equation:

$$PP = \frac{F_{in} h \rho_{water}}{\eta_p} \quad (36)$$

Here, h is the pumping head in m, ρ_{water} is the water density in Kg/m³ and η_p is the pumping efficiency. Blow-down and make-up which are functions of evaporation are calculated as below:

$$B = \frac{E}{(\pi_C - 1)} \quad (37)$$

$$M = E \frac{\pi_C}{(\pi_C - 1)} \quad (38)$$

After the optimization model was constructed, a proper method was used to optimize the performance parameters with respect to the environmental criteria, energy saving target and minimum cost. The presented optimization model, which was constructed using MATLAB was accounted for the optimum water supply line and minimum cost. The optimum water supply line was achieved using the recently presented model, while considering the feasibility definition constraints to obtain optimal performance parameters. An illustrative example is presented to apply the IOTCS design technique to demonstrate the cost-effective optimal configuration of the heat-exchanger network. The result of a different design methodology was demonstrated for comparison.

RESULTS AND DISCUSSION

Illustrative example of IOTCS

In this work, a cooling water system using IOTCS with an optimum network configuration was designed. An analysis for minimizing the total cost and conservation of energy was performed. The process stream data is given in Table 2. The following parameters were used for the illustrative example:

The wet bulb temperature of air is 15 °C, ambient air temperature, 25 °C, minimum approach temperature, 5 °C, pump efficiency, 60%, pumping head, 10.67 m, operating time, 8600 h/y, interest rate, 15%, payback period, 3 y, ΔT_{min} , 10 °C and temperature limitation, 57 °C. Most cooling water design methodologies achieve a cycle concentration of 3. However, using IOTCS design, it increases the cycle of concentration up to 15, which will result in water conservation. Theoretically, 46% saving in water usage can be obtained using the following equation (Prasad, 2004):

$$V = M_i \frac{\pi_{C_i} - \pi_{C_{ii}}}{\pi_{C_i} (\pi_{C_{ii}} - 1)} \quad (39)$$

To achieve the optimum performance parameters of the cooling system, the cooling tower total annual cost function, capital and operational investments, including the blow-down and ozone water treatment

Table 2: Process stream data

Process stream	Heat exchanger	Inlet temperature to heat exchanger (°C)	Outlet temperature of heat exchanger (°C)	C _p (KW/°C)	Q (KW)
1	1	50	40	100	1000
2	2	45	40	100	500
3	3	55	50	200	1000
4	4	65	55	50	500




Fig. 7: Cooling water main method for RCWS design

cost, was solved to achieve the minimum value as possible. In order to obtain optimum parameters, advanced synthesis algorithm was used and consequently an optimal heat-exchanger configuration was achieved.

Operating cost of IOTCS = fan cost + pumping cost + blow-down treatment cost + make-up water cost + ozone water treatment cost.

Capital cost of IOTCS = cooling tower capital cost + ozone water treatment capital cost

The ozone treatment operational cost is included of ozone electricity cost in \$/y and conversion factor. The capital cost of ozone water treatment is a function of water flow rate and can be expressed as follows (Parker, 1998):

$$\text{Ozone capital cost} = 24.43 (F_{in}) + 10^4 \quad (40)$$

$$\text{Ozone electricity cost} = 24.43 (F_{in}) \quad (41)$$

The inlet water flow rate is in T/h.

The synthesis algorithm by setting up the water mains at water supply temperature, pinch points temperatures and exit temperature (Fig. 7) was used for developing an optimal heat-exchangers network configuration (Fig. 8) (Mann and Liu, 1999). This synthesis algorithm was based on the composite curve decomposition and water main method. The water main method of Kuo and Smith (1997) for the design of water reuse networks can be extended to the design of cooling water networks. The original method identified water reuse opportunities for problems in which reuse was constrained by concentration limits. This method was carried out in four steps. The first step was to generate a grid diagram with cooling water mains and plot the cooling water using operations as shown in Fig. 7. The second stage was to connect the operations with cooling water mains. The third stage was to merge operations that cross mains. The final stage was to remove intermediate (pinch) cooling water mains. Following the method allows the design of the cooling water network to achieve the target predicted by the supply line. Details of the procedure are given by Kuo and Smith (1997) and readily adapted to the concentration constraints in the original paper to the temperature constraints that are a feature of the cooling water network design problem. In order to achieve an optimum water supply line in the feasible region, using a limiting profile, which is defined from either pinch point or cooling tower temperature limitation, was considered as a guide that represents the boundary




Fig. 8: Optimum heat-exchanger configuration of IOTCS design




Fig. 9: Heat-exchanger configuration of KSD

Table 3: Performance parameters using various design methods

Design method	$T_{hot,in}$ (°C)	$T_{cold,out}$ (°C)	C_p (KW/°C)	F (t/h)	e (%)
Conventional	40.46	30	286.67	246.89	41
KSD	45	30	200	172.24	50
IOTCS	48.35	28.22	149	128.32	60

Table 4: Cost comparison of various design methods K\$/y

Design method	OC	CC	TC
Conventional	65.90	6.54	72.44
KSD	53.66	6.04	59.70
IOTCS	20.20	19.55	39.75

Table 5: Make-up, blow-down water and energy saving of various design methods relative to KSD

Design method	Make up (t/h)	Blow down (t/h)	Energy (KW)	Make up saving (%)	Blow down saving (%)	Energy saving (%)
Conventional	7.90	3.95	17.42	-	-	-
KSD	7.90	3.95	13	-	-	-
IOTCS	4.23	0.28	10.63	46	93	17

between feasible and infeasible operation. The optimum design construction and optimum heat-exchanger configuration were then accomplished considering the maximum water reuse profile and water pinch synthesis (Fig. 8). As in Fig. 8 is shown, the optimum configuration achieved through IOTCS design methodology provides more series arrangement opportunities in comparison with the KSD method (Fig. 9). Table 3 shows the optimum water flow rate and temperature of cooling water system, using IOTCS design. Table 4 illustrates that IOTCS obtains the minimum total cost achievable in comparison with the KSD design methodology. By integrating ozone water treatment and constraint identification, and in search for the optimum arrangement, the cost analysis results of the total parallel configuration (Conventional design) KSD and IOTCS are demonstrated in Table 4.

Table 5 shows the water and energy saving processes in both the design methods of KSD and IOTCS. As shown in Table 5, the IOTCS design method resulted in a 17% energy saving relative to the KSD method. Fig. 10 shows the cost comparison of conventional, KSD and IOTCS design methods. As the presented illustrative example indicates, the results show that the total cost of the IOTCS design method resulted in the total cost of 39.75 K\$/y as compared to the KSD total cost of 59.70 K\$/y and 72.44 K\$/y for the conventional design. Optimization was




Fig. 10: Cost comparison of Conventional, KSD and IOTCS design methods

made using MATLAB version 7.3. The results of the analysis for a four-stream illustrative case demonstrated 46% of make-up, 93% of blow-down water and 17% of energy saving relevant to the KSD method. Consequently, applying the IOTCS methodology to the industrial large-scale problems provided more water and energy conservational opportunities.

Nomenclature

- RCWS Re-circulating cooling water system
- KSD Kim & Smith design
- IOTCS Integrated ozone treatment cooling system
- F_0 Inlet water flow to heat-exchanger network (t/h)
- F_1 Outlet water flow rate of cooling tower (t/h)
- M Make up (t/h)
- B Blow down (t/h)
- F_2 Inlet water flow rate to cooling tower (t/h)
- T_0 Inlet water temperature of heat-exchanger network (°C)
- T_1 Outlet temperature of water (°C)
- T_2 Inlet water temperature (°C)
- T_M Water make-up temperature (°C)
- D Drift Loss (t/h)
- Q_{HEN} Overall network heat duty (MJ)
- C_p Water Heat capacity (MJ/t.°C)
- m_a Air flow rate at control volume
- m_w Water flow rate at control volume
- Z Cooling tower height (m)
- w_{out} Interface humidity ratio
- w_{air} Air humidity ratio
- K_G Mass transfer coefficient of air (m/s)

a_1, b, c	Constant value of mass transfer coefficient
P^S	Vapor pressure (bar)
h_d	Convective heat transfer coefficient (KW/m ² °C)
T_a	Air temperature (°C)
A	Cooling tower area (m ²)
Q_{ACT}	Actual heat removal (MJ)
Q	Maximum heat removal (MJ)
TC	Total cost (K\$/y)
e	Effectiveness (%)
CC	Capital cost (K\$/y)
F_{in}	Cooling system inlet water flow rate (t/h)
P	Total pressure (bar)
E	Evaporation Loss (t/h)
w_{in}	Inlet air humidity (t.water/t.air)
$w_{ga}(WBT)$	Air humidity at wet bulb temp.
C_{pa}	Air heat capacity (MJ/t.°C)
$T_{amb.}$	Ambient temperature (°C)
T_{WB}	Wet bulb temperature (°C)
$w_{sat.}(WBT)$	Sat. humidity at wet bulb temperature
A_0, B_0, C_0	Constant value of vapor pressure
h_a	Air enthalpy (KJ/t)
T_w	Water temperature (°C)
Q	Overall Enthalpy (MJ/t)
Q_m	Enthalpy associated with mass transfer (MJ/t)
Q_c	Enthalpy associated with convective Transfer (MJ/t)
R	Range (°C)
A	Approach (°C)
PP	Pumping power (tKg/m ² h)
F_{air}	Air flow rate (t/h)
OC	Operation cost (K\$/yr)
T_{in}	Cooling tower inlet water temperature (°C)
T_{out}	Cooling tower outlet water temperature (°C)
T_{NR}	Temperature at which no re- use at network (°C)
T_{MR}	Temperature of max. water re-use at network (°C)
T_M	Min. temperature with respect to ΔT_{min} of the network (°C)
T_{TL}	Temperature limitation (°C)
T_M	Minimum approach (°C)
$T_{HEN,min.}$	Minimum network temperature (°C)
T_i^{Pinch}	Temperature at pinch point (°C)
ΔT_{min}	Minimum temperature approach of network (°C)
Q_i^{Pinch}	Heat load at pinch point (MJ)
F_{in}^l	Cooling tower inlet water flow rate lower limit (t/h)
F_{in}^u	Cooling tower inlet water flow rate upper limit (t/h)
h	Pumping head (m)
ρ_{water}	Water density (Kg/m ³)
η_P	Pump efficiency
π_C	Cycle of concentration
X_m	Concentration in make-up
X_B	Concentration in blow down
M_i	Initial make up (t/h)
V_i	Water volume (l)
π_{C_i}	Initial cycle of concentration
$\pi_{C_{ii}}$	New cycle of concentration

REFERENCES

- Alsheyab, M. A. T.; Munoz, A. H., (2007). Optimization of ozone production for water and waste water treatment, *Desalination*, 217 (1), 1-7.
- Bernier, M. A., (1994), Cooling tower performance: Theory and experiments. *ASHRAE T. Res.*, 100 (2), 114-121.
- Castro, M. M.; Pinto, J. M.; Song, T. W., (2000), Operational cost minimization in cooling water system, *Braz. J. Chem. Eng.* 17 (4), 4-7.
- Conner, A., (2005), Reducing cooling towers cost with the ozone technology, *Clean Water Ozone Systems, Inc.*
- Deng, S.; Tan, K., (2003). A numerical analysis of heat and mass transfer inside a reversibly used water cooling tower, *Build. Environ.*, 38 (1), 91-97.
- Fisenko, S. P.; Brin, A. A.; Petruichik, A. I., (2004), Evaporative cooling of water in a mechanical draft cooling tower, *Int. J. Heat Mass Tran.*, 42 (1), 165-177.
- Hasan, A.; Siren, K., (2002), Theoretical and computational analysis of closed wet cooling towers and its applications in cooling of buildings, *Energ. Buildings* , 34 (5), 477-486.
- Heikkila, P.; Milosavljevic, N., (2001), A comprehensive approach to cooling tower design, *Appl. Therm. Eng.* 21 (9), 899-915.
- Hollands, K. G. T., (2003), An analysis of a counterflow spray cooling tower, *Int. J. Heat Mass Tran.*, 17 (10), 1227-1239.
- Kim, J. K.; Smith, R., (2001), Cooling water system design, *Chem. Eng. Sci.*, 56 (12), 3641-3658.
- Kim, J. K.; Savulescu, L.; Smith, R., (2001), Design of cooling systems for effluent temperature reduction, *Chem. Eng. Sci.*, 56 (5), 1811-1830.
- Kaiser, A. S.; Lucas, M.; Viedma, A.; Zamora, B., (2005). Numerical model of evaporative cooling processes in a new type of cooling tower, *Int. J. Heat Mass Tran.*, 48 (5), 986-999.
- Khan, J. R.; Zubair, S. M., (2004). A study of fouling and its effects on the performance of counter flow wet cooling towers, *Process Mech. Eng.* 218 (9), 43-51.
- Khan, J. R.; Yaqub, M.; Zubair, S. M., (2003). Performance characteristics of counter flow wet cooling towers, *Energ. Convers. Manage.*, 44 (13), 2073-2091.
- Khan, J. R.; Qureshi, B. A.; Zubair, S. M., (2004). A comprehensive design and performance evaluation study of counter flow wet cooling towers, *Int. J. Refrig.*, 27 (8), 914-923.
- Kloppers, J. C.; Kröger, D. G., (2005a). The Lewis factor and its influence on the performance prediction of wet-cooling towers, *Int. J. Therm. Sci.*, 44 (9), 879-884.
- Kloppers, J. C.; Kröger, D. G., (2005b). Influence of temperature inversions on wet-cooling tower performance, *Appl. Therm. Eng.*, 25 (8), 1325-1336.
- Kloppers, J. C.; Kröger, D. G., (2005c). Cooling tower performance evaluation: Merkel, Poppe and e-NTU methods of analysis, *Trans. ASME J. Engrg. Gas Turbines Power*, 127 (1), 1-7.
- Kloppers, J. C.; Kröger, D. G., (2004). A critical investigation into the heat and mass transfer analysis of crossflow wet-cooling towers, *Numer. Heat Transfer A. Appl.* 46, 785-806.
- Kröger, D. G., (2002). Air-cooled heat exchangers and cooling towers.

- Kuo, W. J.; Smith, R., (1997). Effluent treatment system design, Chem. Eng. Sci. 52 (23), 4273-4290.
- Mann, J.; Liu, Y. A., (1999), Industrial water reuse and waste water minimization, McGraw-Hill, New York.
- MATLAB software, version 7.3.
- Parker, S. A., (1998). Ozone treatment for cooling tower, The U.S. Department of Energy, Fed. Tech. Alert J., New York.
- Prasad, M., (2004). Economic up gradation and optimal use of multi-cell cross flow evaporative water cooling tower through modular performance, Appl. Therm. Eng., 24 (4), 579-593.
- Pascal, S.; Marchio, D., (2003). Simplified model for indirect-contact evaporative cooling-tower behavior, Appl. Energ., 78 (4), 433-451.
- Qureshi, B. A.; Zubair, S. M., (2006), A complete model for wet cooling towers with fouling in fills, Appl. Therm. Eng., 26 (16), 1982-1989.
- Smith, R., (2005), Chemical process design, John Wiley and Sons publication.
- Strittmatter, R.; Yang, B.; Johnson, D. A., (2003), Application of ozone in cooling water systems, Nalco Chemistry.
- Viera, M. R.; Guiamet, P. S.; de Melle, M. F. L.; Videla, H. A., (2000). Use of dissolved ozone for controlling planktonic and sessile bacteria in industrial cooling systems, Int. Biodeter. Biodegr., 44 (4), 201-207.

AUTHOR (S) BIOSKETCHES

Panjeshahi, M. H., Ph.D., Associate professor in the Department of Chemical Engineering at the University of Tehran, Tehran, Iran and as adjunct associate professor in the Department of Chemical and Petroleum Engineering., University of Calgary, Calgary, Alberta, Canada. Email: mhpanj@ut.ac.ir

Ataei, A., M.Sc., Ph.D. research student in the Department of Energy Engineering, Graduate School of the Environment and Energy, Science and Research Campus, Islamic Azad University, Tehran, Iran. Email: abtinataei@gmail.com

This article should be referenced as follows:

Panjeshahi, M. H.; Ataei, A., (2008). Application of an environmentally optimum cooling water system design in water and energy conservation. Int. J. Environ. Sci. Tech., 5 (2), 251-262.